

ADDENDUM A-02

Project:	Drumheller Flood Mitigation and Resiliency – Dike C – North Drumheller Grove Plaza Dike Project
Addendum:	A-02
Date:	July 8, 2022
Location:	224 Centre Street Drumheller, Alberta

To All Bidders:

General
This addendum shall be read in conjunction with the Specifications prepared for the Request for Tender – Dike C - North Drumheller Grove Plaza Dike Project (2022-06-21C).
1. Tender closing date
Q: We are requesting for one week of tender closing extension for the above noted project. A: Sorry, there will be no extension of the submission date for Grove Plaza Dike.
2. Chain link fence
Q: Existing chain link fence is to be removed and reinstalled. Often, fencing is damaged through this process. Will the owner be paying for replacement materials if damaged during removal? A: Please see Addendum A-01 Question 5
3. Substantial Completion
Q: Substantial completion of November 30th is not realistic. Can the completion date be changed to May of 2023? A: No.
4. Paving
Q: Given the late timeline of the project, it is very likely that paving will not be able to take place. Can the paving be deferred until spring of 2023? A: Paving should be targeted for the fall of 2022. If weather doesn't allow for fall paving, we would consider spring paving, so long as the pathways are left in a serviceable condition over the winter for pedestrian use.
5. Vibration Monitoring
Q: Please confirm vibration monitoring is required. What is expected of the contractor regarding vibration monitoring? A: Vibration monitoring is required. It will be performed by the owner's Engineer.

6. Site Office
<p>Q: Please confirm a site office is needed.</p> <p>A: A site office is needed. See section 01520 of specifications.</p>
7. Temp Fence
<p>Q: Please clarify what type of temp fence is needed. How will the supply, installation, and removal of this be paid?</p> <p>A: See section 01520 of specifications. It will be paid under item no. 1.1 Mobilization and Demobilization.</p>
8. Hydrocarbon Contaminated Soil
<p>Q: Excavation of hydrocarbon contaminated soil is mentioned in the specifications. Is there contaminated material expected to be encountered? If so, how much and how will this be paid to remove?</p> <p>A: Hydrocarbon contaminated soil is not expected. If encountered, it will be addressed with a change order.</p>
9. Hauling
<p>Q: Please confirm that hauling activities will be able to be permitted at 100% axle weights.</p> <p>A: Confirmed, 100% axle weight is permitted for construction in the fall.</p>
10. Workspace agreements
<p>Q: Is approval and agreement in place with the business owner to access the work location through their property? How will the restoration of the existing parking lot be paid?</p> <p>A: See addendum C-01 item 6.</p>
11. Temporary Laydown Areas
<p>Q: Are there any temporary laydown/stockpile areas available?</p> <p>A: Yes, see addendum C-01.</p>
12. Seeding
<p>Q: What application method is to be used for seeding?</p> <p>A: See sections 002910 and 002924 of specifications.</p>

End of Addendum A-02